

# FuelCAN FLC300

## Fuel sender to J1939 CANbus interface

00-02-0663  
28<sup>th</sup> November 2008  
catalogue section 78



### Installation Instructions

Please read the following information before installing. A visual inspection of this product for damage during shipping is recommended before installation. It is your responsibility to ensure that qualified mechanical and electrical technicians install this product. If in doubt, please contact your local Murphy representative.

### GENERAL INFORMATION

⚠ **WARNING** ⚠

**BEFORE BEGINNING INSTALLATION OF THIS PRODUCT**

- ✓ Disconnect all electrical power to the machine
- ✓ Make sure the machine cannot operate during installation
- ✓ Follow all safety warnings of the machine manufacturer
- ✓ Read and follow all installation instructions



### Description

FuelCAN is a compact interface for translating an analogue fuel level sender signal into digital SAE J1939 CANbus data. The device allows integration of standard fuel level senders into modern ECU-based engine instrument and control systems.

FuelCAN modules have three inputs (only one of which is connected at any one time): input 1 is configured for use with Murphy ES series resistive fuel level senders; inputs 2 and 3 can be used with fuel level senders having compatible resistance ranges.

	fuel level / approx. resistance, Ohms				
	empty	1/4	1/2	3/4	full
<b>Input 1 (Murphy)</b>	240	147	96	60	33.5
<b>Input 2</b>	240	158	100	58	30
<b>Input 3</b>	10	56	95	138	180

FuelCAN inputs can also be factory-configured for use with non-standard fuel level or resistive senders. Please note that minimum order quantities apply for custom solutions.

A rear facing LED indicates input and CANbus status. FuelCAN is compact and light enough to be incorporated into wiring harnesses, but can also be surface mounted via four case holes. The polycarbonate case is fully sealed in epoxy resin for high impact and environmental resistance.


These instructions relate to Murphy part number 79.70.0006. FuelCAN modules with other stock codes may include modified input scaling or CANbus/J1939 data parameters.

### Product specification

<b>power supply:</b>	
operating voltage	7 to 35 VDC
current consumption	25mA (typ.)
<b>input:</b>	
max. operating range	-2 to +35 VDC
input 1 sender range, Ohms	240 (empty) to 33.5 (full)
input 2 sender range, Ohms	240 (empty) to 30 (full)
input 3 sender range, Ohms	10 (empty) to 180 (full)
<b>output:</b>	
CANbus	SAE J1939 protocol, PGN 65276 (00FEFC <sub>16</sub> ), 2 sec update rate. 120 Ohm terminating resistor fitted.
<b>physical:</b>	
case material	high-impact ABS, epoxy filled
case dimensions (l x w x h)	100 x 25 x 15 mm / 4.0 x 1.0 x 0.6 in
weight	approx. 60g / 0.13 lb
operating temperature	-20°C to +85°C / -4°F to +185°F
environmental sealing	IP65 case, exposed lead ends
electromagnetic compatibility	2004/108/EC

### Connection & dimensions

(standard FLC300 shown)



# ELECTRICAL CONNECTION & FIXING

## Electrical Connection

FuelCAN connection is via 8 colour-coded flying leads (see diagram on page 1).

**RED: Power supply positive DC**

**BLACK: Power supply negative DC**

Connect these wires to a smooth DC power supply in the range 7 to 35 VDC. A 1 Amp anti-surge fuse is recommended in the positive DC line.

FuelCAN operates with negative earth/ground or fully insulated DC systems. **DO NOT** use FuelCAN with positive earth/ground systems.

**YELLOW: CANbus high**

**GREEN: CANbus low**

Connect these wires to the engine's CANbus, using the appropriate twisted-pair cable to J1939 specification. FuelCAN includes a non-removable 120 Ohm terminating resistor.

**BLACK: Sender common (negative DC)**

**VIOLET: Sender input 1 (Murphy)**

**ORANGE: Sender input 2**

**WHITE: Sender input 3**

For best measurement accuracy, use an insulated return (2-wire) resistive fuel level sender, e.g. (for input 1) Murphy ES2F series. Connect one sender terminal to the appropriate FuelCAN input lead (1, 2 or 3); connect the other sender terminal to FuelCAN's Sender Common (black) wire.

Where a 1-wire (negative DC/ground return) sender is used, connect the black (sender common) wire to battery negative.

## Mounting

FuelCAN uses an epoxy-resin filled, polycarbonate case for high impact and environmental resistance. The case is compact and light enough for inclusion in (or tie-wrapping to) an engine wiring harness; or it can be surface mounted via 4 x M4 (0.15 in) holes - see diagram on page 1 for dimensions. The case is sealed to IP65; the exposed flying leads must use connectors appropriate for the environmental sealing required.

# OPERATION & MAINTENANCE

## Operation

At each power up, FuelCAN checks all three inputs for an in-range sender resistance. If more than one sender is connected at power-up, FuelCAN prioritises input selection in the order 1 (Murphy), 2 then 3.

Once FuelCAN has selected a valid input, it continues to use that input until the DC power supply is cycled. FuelCAN transmits fuel level data every 2 seconds. Data specification is otherwise as SAE J1939-71:

PGN	65276 (00FEFC <sub>16</sub> )
Message data length	8 bytes
Relevant byte	#2 (fuel level)
Data page	0
PDU format	254
PDU specific	252
Resolution	0.4%/bit gain, 0% offset
Data range	0 to 100%

If a sender failure (short or open circuit) occurs during operation, FuelCAN transmits fuel level data of value 0xFE<sub>16</sub> (indicating 'measurement error').

If no valid sender is detected at power-up, FuelCAN transmits a value 0xFF<sub>16</sub> (indicating 'measurement not available') and flashes its LED in a 'heartbeat' pattern (two short pulses, followed by a longer pause). J1939 message PGN65275 also includes bytes for other parameters, including washer fluid level (byte #1), fuel filter

differential pressure (byte #3), engine oil filter differential pressure (byte #4) and cargo ambient temperature (bytes #5/6). For each of these parameters, FuelCAN transmits a value 0xFF<sub>16</sub> (indicating 'measurement not available').

LED operation is as follows:-

LED pattern	Status
Off	Power off
Flashing ('heartbeat' pulse on)	Power on, but all inputs open circuit (valid sender not detected).
Flashing (50/50% on/off)	Power on, valid sender input, but no CAN activity.
On	Power on, valid sender input and CAN activity

## Maintenance and Warranty

FuelCAN contains no user-serviceable parts. Maintenance is therefore limited to the following preventative checks:

- Check that FuelCAN electrical connections are secure.
- Check that the case is mounted securely, with vibration and environmental exposure minimised where possible. The case may be wiped with a clean, damp cloth. Do not use cleaning solvents.

FuelCAN is supplied with a two year warranty on parts and workmanship. In the event of a fault or technical query, and before returning equipment, please contact your Murphy representative for technical support.

*In order to consistently bring you the highest quality, full featured products, we reserve the right to change our specifications and designs at any time. MURPHY, the Murphy logo, are registered and/or common law trademarks of Murphy Industries, Inc. This document, including textual matter and illustrations, is copyright protected by Frank W Murphy Ltd., with all rights reserved. © 2008 Frank W Murphy Ltd.*

### FW MURPHY

P.O.Box 470248, Tulsa, Oklahoma 74147 USA  
+1 918 317 4100 Fax: +1 918 317 4266  
E-mail: sales@fwmurphy.com

### INDUSTRIAL PANEL DIVISION

Fax: +1 918 317 4124  
E-mail: ipdsales@fwmurphy.com

### MURPHY POWER IGNITION

Website: www.murphy-pi.com

### CONTROL SYSTEMS AND SERVICES DIVISION

P.O.Box 1819, Rosenberg, Texas 77471 USA  
Phone: +1 281 633 4500 Fax: +1 281 633 4588  
E-mail: sales@fwmurphy.com

### FRANK W. MURPHY LTD.

Church Rd, Laverstock,  
Salisbury, SP1 1QZ, United Kingdom  
Tel: +44 1722 410055  
Fax: +44 1722 410088  
E-mail: sales@fwmurphy.co.uk  
Web: www.fwmurphy.co.uk

### COMPUTRONIC CONTROLS

41 - 43 Railway Terrace, Nechells,  
Birmingham, B7 5NG, United Kingdom  
Tel: +44 121 327 8500  
Fax: +44 121 327 8501  
E-mail: sales@computroniccontrols.com  
Web: www.computroniccontrols.com

### FW MURPHY INTERNATIONAL TRADING (SHANGHAI) CO. LTD.

Suite 1704, Tower B, City Centre of Shanghai, 100 Zunyi Road,  
Shanghai, 200051 China  
Phone: +86 21 6237 2082 Fax: +86 21 6237 2083  
E-mail: mhong@fwmurphy.com

### FW MURPHY INSTRUMENTS (HANGZHOU) CO. LTD.

77 23<sup>rd</sup> Street, Hangzhou Economic & Technological Development Area  
Hangzhou, Zhejiang 310018 China  
Phone: +86 571 8788 6060 Fax: +86 571 8684 8878

